

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7271-1501:136 Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: Edwards, 90 Fieldstone Ct., Cheshire, CT 06410
Contact: David Mazur (203) 699-3155

DESIGN: Model CSBU-1 smoke detector base. Base is for use with Models SC10U-3, SC30U-3, smoke detector heads and Models SC20FTU-3 and SC20RRU-3 heat detector heads. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as an ionization smoke detector base for use with separately listed compatible fire alarm control units.

XLF: 7271-1591:214

12-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **DECEMBER 12, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager